

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Fixed luminaires with LED and limited surface temperature

Name and address of the applicant

ZALUX S.A.
Avda. Manuel Rodriguez Ayuso 114 Centro Empresarial Miralbueno,
Planta 1a, Local P-2, 50012 Zaragoza, Spain

Name and address of the manufacturer

ZALUX S.A.
Avda. Manuel Rodriguez Ayuso 114 Centro Empresarial Miralbueno,
Planta 1a, Local P-2, 50012 Zaragoza, Spain

Name and address of the factory

Zalux S.A.
Avenida Aragon 54, 50230 Alhama De Aragon, Spain*When more than one factory* Additional information on page 2

Ratings and principal characteristics

Product dataRatings for all types: 220-240 V; 0/50-60Hz (DHE..., DSTP...) or 50-60Hz (DST...); class I; max. 51 W; IP66; 4000K
For further ratings refer to test report.

Trademark / Brand (if any)

ZALUX

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

DHE 1.2 32-840 ETDD x y z #, DHE 1.2 32-840 ET x y z #,
DHE 1.2 40-840 ETDD x y z CG #, DHE 1.2 40-840 ET x y z CG #,
DHE 1.5 60-840 ETDD x y z CG #, DHE 1.5 60-840 ET x y z CG #,
DHE 1.5 80-840 ETDD x y z CG #, DHE 1.5 80-840 ET x y z CG #,
DSTP 1.2 40-840 ETDD x y IX-U #, DSTP 1.2 40-840 ET x y IX-U #,
DSTP 1.2 40-840 ET x y z #, DSTP 1.5 60-840 ETDD x y IX-U #,
DSTP 1.5 60-840 ET x y IX-U #, DSTP 1.5 60-840 ET x y z #,
DST 1.2 40-840 ET x y PA-U #, DST 1.2 40-840 ET x y z #,
DST 1.5 60-840 ET x y PA-U # and DST 1.5 60-840 ET x y z #

Additional information

 Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60598-1:2020, IEC 60598-2-1:2020 and IEC 60598-2-24:2013

National differences:
EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

3433498.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2024-09-24

Signature: B. Menzel

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

[Additional information](#)

Abbreviations in type designation:

- x Marking for material of housing: PC or SMC
- y Marking for material of cover: DPC (PC) or DPM (PMMA)
- z Marking for material of mounting clip: PA or INOX / IX
- # Marking for through wiring: blank or 3x1.5 or 5x1.5 or 5x2.5
- U Marking for undismountable clips / Luminaire without internal diffusor

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands



Date: 2024-09-24

Signature: B. Menzel